



ENERGY COST AND FEATURE REPORT

Date:	August 06, 2009	Rating No.:	CL090730DELAFLEUR
Building Name:	DE LA FLEUR HOME	Rating Org.:	GREEN DREAM GROUP, LLC
Owner's Name:	MARCUS DE LA FLEUR	Phone No.:	773.271.5310
Property:	3141 W. 15th St.	Rater's Name:	CORBETT LUNSFORD
Address:	CHICAGO, IL 60623	Rater's No.:	CL1040
Builder's Name:	SELF		
Weather Site:	Chicago, IL	Rating Type:	Projected Rating
File Name:	DELAFLEUR-PORCHCONDITIONEDSUNWINDC	Rating Date:	07/30/2009

DE LA FLEUR HOME

ANNUAL ENERGY COSTS

Heating	\$	565
Cooling	\$	0
Water Heating	\$	0
Lights & Appliances	\$	1402
Photovoltaics	\$	-189
Service Charges	\$	264
Total	\$	2042
Average Monthly	\$	170

ENERGY FEATURES

Ceiling w/Attic:	None
Vaulted Ceiling:	R-52 Foam INT. U=0.020
Above Grade Walls:	R-21, R-10 CONT. U=0.043
Foundation Walls (Cond):	R-21, R-10 CONT INT R=21.0
Found. Walls (Uncond):	None
Doors:	Steel-urth w/brk U=0.187
Windows:	Dbl/LoE/Argon-Wood+ U=0.250
Frame Floors:	None
Slab Floors:	R-5 Under Slab U=0.087
Infiltration:	Htg: 0.20 Clg: 0.20 ACHnat
Infilt. Measure:	Blower door test
Mechanical Ventilation:	Balanced: ERV, 300 cfm, 250.0 watts.
Interior Mass:	None
Mech Equip List:	Heating: Fuel-fired hydronic distribution, 60.0 kBtuh, 90.0 AFUE.
	Water Heating: Conventional, Gas, 0.63 EF.
Programmable Thermostat:	Heat=Yes; Cool=Yes

ENERGY COST AND FEATURE REPORT

DE LA FLEUR HOME

Page 2

Ducts:	NA
Duct Leakage:	NA
Lights/Appliances:	Defaults
Active Solar:	DHW & space heating
Photovoltaics:	2000 DC Watts
Sunspace:	No

Notes: Where feature level varies in home, the dominant value is shown.



EQUIPMENT SIZING SUMMARY

Date:	August 06, 2009	Rating No.:	CL090730DELAFLEUR
Building Name:	DE LA FLEUR HOME	Rating Org.:	GREEN DREAM GROUP, LLC
Owner's Name:	MARCUS DE LA FLEUR	Phone No.:	773.271.5310
Property:	3141 W. 15th St.	Rater's Name:	CORBETT LUNSFORD
Address:	CHICAGO, IL 60623	Rater's No.:	CL1040
Builder's Name:	SELF		
Weather Site:	Chicago, IL	Rating Type:	Projected Rating
File Name:	DELAFLEUR-PORCHCONDITIONEDSUNWINDC	Rating Date:	07/30/2009

DE LA FLEUR HOME

HEATING

Calculated Peak Load (kBtu/hr)	48.6
Sizing Factor (%)	100.0

HEATING EQUIPMENT CAPACITY (kBtu/hr)

Required	48.6
Specified	60.0

COOLING

Calculated Peak Load (kBtu/hr)	0.0
Sensible	0.0
Latent	0.0
Sizing Factor (%)	0.0

COOLING EQUIPMENT CAPACITY (kBtu/hr)

Required Total	0.0
Specified Total	0.0

Required Sensible	0.00
Specified Sensible	0.00

Required Latent	0.00
Specified Latent	0.00



PERFORMANCE SUMMARY

Date:	August 06, 2009	Rating No.:	CL090730DELAFLEUR
Building Name:	DE LA FLEUR HOME	Rating Org.:	GREEN DREAM GROUP, LLC
Owner's Name:	MARCUS DE LA FLEUR	Phone No.:	773.271.5310
Property:	3141 W. 15th St.	Rater's Name:	CORBETT LUNSFORD
Address:	CHICAGO, IL 60623	Rater's No.:	CL1040
Builder's Name:	SELF		
Weather Site:	Chicago, IL	Rating Type:	Projected Rating
File Name:	DELAFLEUR-PORCHCONDITIONEDSUNWINDC	Rating Date:	07/30/2009

DE LA FLEUR HOME

Annual Load (MMBtu/yr)

Heating	57.3
Cooling	0.0
Water Heating	0.0

Annual Consumption (MMBtu/yr)

Heating	64.2
Cooling	0.0
Water Heating	0.0
Lights & Appliances	59.9
Photovoltaics	-8.1
Total	116.0

Annual Energy Cost (\$/yr)

Heating	\$	565
Cooling	\$	0
Water Heating	\$	0
Lights & Appliances	\$	1402
Photovoltaics	\$	-189
Service Charges	\$	264
Total	\$	2042

Design Loads (kBtu/hr)

Space Heating	48.6
Space Cooling	0.0

Utility Rates:

Electricity:	CHICAGO ELECTRIC
Gas:	CHICAGO GAS



COMPONENT LOAD SUMMARY

Date:	August 06, 2009	Rating No.:	CL090730DELAFLEUR
Building Name:	DE LA FLEUR HOME	Rating Org.:	GREEN DREAM GROUP, LLC
Owner's Name:	MARCUS DE LA FLEUR	Phone No.:	773.271.5310
Property:	3141 W. 15th St.	Rater's Name:	CORBETT LUNSFORD
Address:	CHICAGO, IL 60623	Rater's No.:	CL1040
Builder's Name:	SELF		
Weather Site:	Chicago, IL	Rating Type:	Projected Rating
File Name:	DELAFLEUR-PORCHCONDITIONEDSUNWINDC	Rating Date:	07/30/2009

DE LA FLEUR HOME

HEATING SEASON (MMBtu/yr)

Ceilings/Roofs	6.2
Rim/Band Joists	3.3
Above Grade Walls	18.6
Foundation Walls	9.7
Doors	2.9
Windows/Skylights	10.1
Frame Floors	0.0
Crawl Space/Unht Bsmt	0.0
Slab Floors	5.6
Infiltration	30.5
Mechanical Ventilation	2.5
Ducts	0.0
Active Solar	-7.0
Sunspace	0.0
Internal Gains	-25.1
Total	57.3

DE LA FLEUR HOME



FUEL SUMMARY

Date:	August 06, 2009	Rating No.:	CL090730DELAFLEUR
Building Name:	DE LA FLEUR HOME	Rating Org.:	GREEN DREAM GROUP, LLC
Owner's Name:	MARCUS DE LA FLEUR	Phone No.:	773.271.5310
Property:	3141 W. 15th St.	Rater's Name:	CORBETT LUNSFORD
Address:	CHICAGO, IL 60623	Rater's No.:	CL1040
Builder's Name:	SELF		
Weather Site:	Chicago, IL	Rating Type:	Projected Rating
File Name:	DELAFLEUR-PORCHCONDITIONEDSUNWINDC	Rating Date:	07/30/2009

DE LA FLEUR HOME

Annual Energy Cost (\$/yr)

Natural gas	\$	553
Electric	\$	1226

Annual End-Use Cost (\$/yr)

Heating	\$	565
Cooling	\$	0
Water Heating	\$	0
Lights & Appliances	\$	1402
Photovoltaics	\$	-189
Service Charges	\$	264
Total	\$	2042

Annual End-Use Consumption

Heating (Therms)	637
Heating (kWh)	153
Lights & Appliances (kWh)	17531
Photovoltaics (kWh)	-2364

Annual Energy Demands (kW)

Heating	0.1
Cooling	0.0
Water Heating (Winter Peak)	0.0
Water Heating (Summer Peak)	0.0
Lights & Appliances (Winter Peak)	1.5
Lights & Appliances (Summer Peak)	3.1
Total Winter Peak	1.5
Total Summer Peak	3.1

FUEL SUMMARY

DE LA FLEUR HOME

Page 2

Utility Rates:

Electricity: CHICAGO ELECTRIC
Gas: CHICAGO GAS



AIR LEAKAGE REPORT

Date:	August 06, 2009	Rating No.:	CL090730DELAFLEUR
Building Name:	DE LA FLEUR HOME	Rating Org.:	GREEN DREAM GROUP, LLC
Owner's Name:	MARCUS DE LA FLEUR	Phone No.:	773.271.5310
Property:	3141 W. 15th St.	Rater's Name:	CORBETT LUNSFORD
Address:	CHICAGO, IL 60623	Rater's No.:	CL1040
Builder's Name:	SELF		
Weather Site:	Chicago, IL	Rating Type:	Projected Rating
File Name:	DELAFLEUR-PORCHCONDITIONEDSUNWINDC	Rating Date:	07/30/2009

Whole House Infiltration	Blower door test	
	<i>Heating</i>	<i>Cooling</i>
Natural ACH:	0.20	0.20
ACH @ 50 Pascals:	3.03	4.06
CFM @ 25 Pascals:	1767	2371
CFM @ 50 Pascals:	2773	3721
Eff. Leakage Area:	152.3	204.3
Specific Leakage Area:	0.00018	0.00024
ELA/100 sf shell:	1.44	1.94

Total Duct Leakage to Outside	
CFM @ 25 Pascals:	N/A
CFM25 / CFMfan:	N/A
CFM25 / CFA:	N/A
CFM per Std 152:	N/A
CFM per Std 152 / CFA:	N/A
CFM @ 50 Pascals:	N/A
Eff. Leakage Area:	N/A
Thermal Efficiency:	0.00

Ventilation	
Mechanical:	Balanced
Sensible Recovery Eff. (%):	95.0
Total Recovery Eff. (%):	95.0
Rate (cfm):	300
Hours/Day:	24.0
Fan Watts:	250.0
Cooling Ventilation:	Natural Ventilation

ASHRAE 62.2 - 2003 Ventilation Requirements

For this home to comply with ASHRAE Standard 62.2 - 2003 Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings, a minimum of 98 cfm of mechanical ventilation must be provided continuously, 24 hours per day. Alternatively, an intermittently operating mechanical ventilation system may be used if the ventilation rate is adjusted accordingly. For example, a 195 cfm mechanical ventilation system would need to operate 12 hours per day, as long as the system operates to provide required average ventilation once each hour.

REM/Rate - Residential Energy Analysis and Rating Software v12.61

This information does not constitute any warranty of energy cost or savings.
© 1985-2008 Architectural Energy Corporation, Boulder, Colorado.